



Cement Mill Test Report

Month of Issue: June 2024

Plant: Harleyville, South Carolina
Product: Masonry Cement Type S
Silo: 11
Manufactured: May 2024

ASTM C91 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	3
Time of setting, Gillmore method: Initial set, minutes	90 min 1000 max	220
Compressive strength (MPa, [PSI]) 7 days	9.0 [1300] min	16.0 [2310]
28 days (Reflects previous month's data)	14.5 [2100] min	21.5 [3120]
Air content of mortar (%)	8 min 19 max	15
Water Retention (% of original flow)	70 min	87

Analysts: Richard Buford, George Wren, Neil Graham

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C91.

Certified By:

Argos USA
Harleyville Plant
463 Judge Street, Harleyville, South Carolina 29448
Phone: 843-806-2244

Sean J. Makens - Quality Manager
Report created: 6/4/2024