



# Cement Mill Test Report

Month of Issue: September 2024

**Plant:** Atlanta, GA Plant  
**Product:** Masonry Cement Type S  
**color:** Gray  
**Manufactured:** August 2024

## ASTM C91 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	9
Time of setting, Gillmore method: Initial set, minutes	90 min 1000 max	230
Compressive strength (MPa, PSI) 7 days 28 days (Reflects previous month's data)	9.0 (1300) 14.5 (2100)	14.0 (2030) 16.5 (2400)
Air content of mortar (%)	8 min 19 max	17
Water Retention (% of original flow)	70 min	77

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C91.

Argos USA - Atlanta Plant  
2520 Paul Ave. NW 30318  
Phone: 404.792.6156

Certified By

Sonya Becknel - Quality Manager  
9/11/2024