



Cement Mill Test Report

Month of Issue: May 2024

Plant: Atlanta, GA Plant
Product: Masonry Cement Type S
color: White
Manufactured: April 2024

ASTM C91 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	8
Time of setting, Gillmore method: Initial set, minutes	90 min 1000 max	230
Compressive strength (MPa, PSI) 7 days 28 days (Reflects previous month's data)	9.0 (1300) 14.5 (2100)	18.1 (2630) 21.7 (3140)
Air content of mortar (%)	8 min 19 max	14
Water Retention (% of original flow)	70 min	78

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C91.

Argos USA - Atlanta Plant
2520 Paul Ave. NW 30318
Phone: 404.792.6156

Certified By

Sonya Becknel - Quality Manager
5/8/2024